



I

NHS Wales

---

# NVCC ENABLING WORKS

## Air Quality Monitoring Quarterly Report





NHS Wales

---

# NVCC ENABLING WORKS

## Air Quality Monitoring Quarterly Report

**TYPE OF DOCUMENT (VERSION) PUBLIC**

**PROJECT NO. 70066877**

**OUR REF. NO. 001**

**DATE: AUGUST 2022**

**WSP**

The Forum  
Barnfield Road  
Exeter, Devon  
EX1 1QR

Phone: +44 1392 229 700

Fax: +44 1392 229 701

WSP.com





# QUALITY CONTROL

---

Issue/revision	First issue	Revision 1	Revision 2	Revision 3
Remarks	Quarterly Report			
Date	31/08/2022			
Prepared by	Caroline Odbert			
Signature				
Checked by	Peter Walsh			
Signature	<i>P. S. Walsh</i>			
Authorised by	Peter Walsh			
Signature	<i>P. S. Walsh</i>			
Project number	70066877			
Report number	Q002			
File reference	\\uk.wspgroup.com\central data\Projects\700668xx\70066877 - nVCC Enabling Works\03 WIP\Air Quality\Reports\Reports\Quarterly Reports			





# CONTENTS

---

<b>EXECUTIVE SUMMARY</b>	<b>1</b>
<b>1. INTRODUCTION</b>	<b>3</b>
<b>2. MONITORING METHODOLOGY</b>	<b>3</b>
<b>2.1. MONITORING TECHNIQUES</b>	<b>3</b>
<b>2.2. AIR QUALITY OBJECTIVES AND STANDARDS</b>	<b>5</b>
<b>2.3. DEFRA AIR QUALITY INDEX</b>	<b>5</b>
<b>3. MONITORING RESULTS</b>	<b>7</b>
<b>3.1. NO<sub>2</sub> DIFFUSION TUBES</b>	<b>7</b>
<b>3.2. ZEPHYR CONTINUOUS MONITOR</b>	<b>8</b>
<b>3.3. DM11</b>	<b>11</b>
<b>4. SUMMARY</b>	<b>13</b>

---

---

## ***APPENDICES***

APPENDIX A MONITORING LOCATIONS

## EXECUTIVE SUMMARY

WSP has been commissioned by NHS Wales to undertake air quality monitoring to meet Cardiff Councils (CC) Pre-commencement planning condition 11 in relation to the Temporary Construction Access Route for the Construction of the Approved Velindre Cancer Centre, Cardiff, CF14 7XB.

During construction works there is the potential for air quality impacts from the generation of dust and particulate matter, which could lead to dust soiling and human health impacts at relevant sensitive receptors. There is also the potential for increases in pollutant emissions from construction vehicles using the local road network.

This report provides a summary of the monitoring data for the period between 6<sup>th</sup> April 2022 and 15<sup>th</sup> July 2022. Defra's Air Quality Index<sup>1</sup> has been used to provide a useful indication of the levels of air pollution (See Figure 2-1 in main report). The index is divided into four bands (low (green), moderate (yellow/orange), high (red), very high (purple)). Summary tables of the monitored concentrations is provided below, the background colour assigned to each of the cells corresponds to Defra's Air Quality Index. All concentrations were low and below the relevant Air Quality Objectives.

### Summary of Average Monitored Diffusion Tube Nitrogen Dioxide (NO<sub>2</sub>) Concentrations\*

Monitor Type	Location	NO <sub>2</sub> Concentration (µg/m <sup>3</sup> )	
		Annual Average (annualised and bias-adjusted)	
Diffusion Tube	Vel 1: Lamppost 15, Park Road	22.2	
	Vel 2: Lamppost 17, Corner of Park Road and Park	22.6	
	Lamppost 25, Pendwyallt Road opposite Lon Y Celyn	20.9	
	Vel 4: Lamppost 1, Hollybush Inn	22.5	
	Vel 5: Lamppost 7, Pendywyallt Road opposite No. 32	31.1	
	Vel 6: Coryton Junior School	12.3	
	Vel 8: Coryton Junior School – side entrance	13.7	

\* Annual average based on monitoring data for period 18<sup>th</sup> January to 15<sup>th</sup> July 2022.

### Summary of Monitored Zephyr Nitrogen Dioxide (NO<sub>2</sub>) Concentrations (7<sup>th</sup> April to 15<sup>th</sup> July 2022)

Monitor Type	Location	NO <sub>2</sub> Concentration (µg/m <sup>3</sup> )	
		Average	Maximum
Zephyr Monitors	Lamppost 1, Hollybush Inn	17.4	70.6
	Lamppost 15, Park Road	15.7	52.5

<sup>1</sup> <https://uk-air.defra.gov.uk/air-pollution/daq>

**Summary of Monitored Zephyr Particulate Matter (PM<sub>10</sub> and PM<sub>2.5</sub>) Concentrations (7<sup>th</sup> April to 15<sup>th</sup> July 2022)**

Monitor Type	Location	PM <sub>10</sub> Concentration (µg/m <sup>3</sup> )			PM <sub>2.5</sub> Concentration (µg/m <sup>3</sup> )	
		Average	Maximum	Maximum 24-hour mean	Average	Maximum
Zephyr Monitors	Lamppost 1, Hollybush	11.4	88.8	32.1	8.5	48.9
	Lamppost 15, Park	10.5	43.1	30.5	7.9	27.3

**Summary of Monitored DM11 Pro Particulate Matter (PM<sub>10</sub> and PM<sub>2.5</sub>) Concentrations (7<sup>th</sup> April to 15<sup>th</sup> July 2022)**

Monitor Type	Location	PM <sub>10</sub> Concentrations (µg/m <sup>3</sup> )			PM <sub>2.5</sub> Concentrations (µg/m <sup>3</sup> )	
		Average	Maximum	Maximum 24-hour mean	Average	Maximum
DM11 Pro	19 Park Road	6.1	23.5	12.1	5.1	22.5

## 1. INTRODUCTION

---

- 1.1.1. WSP has been commissioned by NHS Wales to undertake air quality monitoring to meet Cardiff Councils (CC) Pre-commencement planning condition 11 in relation to the Temporary Construction Access Route for the Construction of the Approved Velindre Cancer Centre, Whitchurch Hospital, Park Road, Whitchurch, Cardiff, CF14 7XB.
- 1.1.2. Condition 11 (CC Reference: 20/01110/MJR) states that:
- “Prior to commencement of the development hereby approved details of an air monitoring unit and its location shall be submitted to and approved in writing with the Local Planning Authority. The monitoring unit shall be implemented in accordance with the approved details and remain operational until cessation of the development. Data from the air monitoring unit shall be provided to the Local Planning Authority on request.*
- Reason: To monitor air quality in accordance with Policy EN13 of the adopted Cardiff Local Plan (2006-2026).’*
- 1.1.3. During construction works there is the potential for air quality impacts from the generation of dust and particulate matter, which could lead to dust soiling and human health impacts at relevant sensitive receptors. There is also the potential for increases in pollutant emissions from construction vehicles using the local road network.
- 1.1.4. In order to discharge the pre-commencement planning condition 11, on behalf of NHS Wales, WSP is carrying out monitoring in the study area using Nitrogen Dioxide (NO<sub>2</sub>) diffusion tubes and using Zephyr and DM11 Pro continuous monitors. The air quality monitoring within the study area is being undertaken to ensure that dust and vehicle exhaust emissions from construction traffic are monitored and effectively managed. This report provides a summary of the monitoring data for the period between 6<sup>th</sup> April 2022 and 15<sup>th</sup> July 2022.

## 2. MONITORING METHODOLOGY

---

### 2.1. MONITORING TECHNIQUES

#### DIFFUSION TUBE MONITORING

- 2.1.1. The diffusion tubes are passive samplers which are used to measure ambient concentrations of NO<sub>2</sub>. The tubes are designed to provide an indication of longer-term average NO<sub>2</sub> concentrations and are useful in identifying areas of high concentrations in relation to road traffic emissions. They are not suitable for identifying short-term pollution events. In order to compare how well the diffusion tubes are performing against a reference method (i.e. a continuous analyser), three tubes have been co-located with the Castle Street continuous monitoring site.
- 2.1.2. The diffusion tubes have been located at 7 locations on accessible points along the main road network and where possible at relevant receptors (e.g. school) to assess any changes in NO<sub>2</sub> concentrations at those locations as a result of the construction traffic (see Table 2-1 and Figure in Appendix A). The tubes are changed over typically every 4 weeks and are then sent to Gradko Laboratories for analysis.

**Table 2-1 - Diffusion Tube Monitoring Locations**

Tube ID	Location	X (m)	Y (m)
Vel 1	Lamppost 15, Park Road	314782	180711
Vel 2	Lamppost 17, Corner of Park Road and Park Avenue	314723	180758
Vel 3	Lamppost 25, Pendwyallt Road opposite Lon Y Celyn	314537	180951
Vel 4	Lamppost 1, Hollybush Inn	314520	180993
Vel 5	Lamppost 7, Pendwyallt Road opposite No. 32	314348	181128
Vel 6	Coryton Junior School	314321	181107
Vel 8	Coryton Junior School – side entrance	314291	181157

## CONTINUOUS MONITORS

- 2.1.3. Concentrations of Particulate Matter (PM<sub>10</sub> and PM<sub>2.5</sub>) and NO<sub>2</sub> are being continuously monitored at two locations within the study area (See Table 2-2 and Figure in Appendix A). There is a Zephyr monitor (NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub>) located close to the Hollybush Estate site and a Zephyr monitor (NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub>) and DM11 Pro monitor (PM<sub>10</sub> and PM<sub>2.5</sub>) located closer to the construction site entrance. The Zephyr monitors were installed on 28<sup>th</sup> February 2022 and the DM11 Pro began monitoring concentrations on the 5<sup>th</sup> April 2022.
- 2.1.4. The Zephyr and DM11 Pro are able to detect localised pollution events and fluctuations in the concentrations and can send alerts to the project team when concentrations go above a certain threshold. The Zephyr continuous monitoring devices are supplied by Earthsense and the DM11 Pro by Air Quality Monitors, data from each of the monitors is uploaded onto a cloud system/website where it can be viewed and downloaded by specific individuals.

**Table 2-2 - Continuous Monitor Locations**

Monitor ID		Location	X (m)	Y (m)
Zephyr	111	Lamppost 1, Hollybush Inn	314520	180993
	942	Lamppost 15, Park Road	314782	180711
DM11 Pro	332	19 Park Road	314887	180597

## 2.2. AIR QUALITY OBJECTIVES AND STANDARDS

- 2.2.1. The Government's policy on air quality within the UK is set out in the Air Quality Strategy for England, Scotland, Wales and Northern Ireland (AQS)<sup>2</sup>. The AQS provides a framework for reducing air pollution in the UK with the aim of meeting the requirements of European Union legislation<sup>3</sup>.
- 2.2.2. The air quality standards are levels recommended by the Expert Panel on Air Quality Standards (EPAQS) and the World Health Organisation (WHO) with regards to current scientific knowledge about the effects of each pollutant on health and the environment.
- 2.2.3. The air quality objectives are policy-based targets set by the Government, which take into account economic efficiency, practicability, technical feasibility and timescale. Some objectives are equal to the EPAQS recommended standards or WHO guideline limits, whereas others involve a margin of tolerance, i.e. a limited number of permitted exceedances of the standard over a given period.
- 2.2.4. The relevant standards and objectives for this monitoring programme are given in below.

**Table 2-3 – Relevant Air Quality Objectives and Standards**

Pollutant	Concentration ( $\mu\text{g}/\text{m}^3$ )	Duration	Exceedances Allowed
Nitrogen Dioxide	200	1-hour mean	18
	40	Annual mean	-
Particulate matter ( $\text{PM}_{10}$ )	40	Annual mean	-
	50	24-hour mean	35
Particulate matter ( $\text{PM}_{2.5}$ ) *	20	Annual mean	-

\* Local Authorities are required to work towards reducing emissions/concentrations of particulate matter within their administrative area, however, there is no statutory objective given in the AQS for  $\text{PM}_{2.5}$  at this time, only a framework.

## 2.3. DEFRA AIR QUALITY INDEX

- 2.3.1. A summary of available monitored concentrations for the period April to July 2022 are provided in Section 3. In addition, to the monitored concentrations, reference is also made to Defra's Air Quality Index<sup>4</sup> which provides a useful indication of the levels of air pollution. The index is divided into four bands (low, moderate, high, very high), and the index is numbered from 1 to 10 within these bands (Figure 3). The bandings are based on hourly mean concentrations, however, can be used in relation to the diffusion tube monitoring results to provide an indication of the levels of air pollution.

<sup>2</sup> Department for Environment, Food and Rural Affairs (Defra) and the Devolved Administrations (2007). The Air Quality Strategy for England, Scotland, Wales and Northern Ireland (Volumes 1 and 2)

<sup>3</sup> The UK formally left the EU on 31<sup>st</sup> January 2020 and new air quality legislation for the UK will be brought forward in due course. The Air Quality (Miscellaneous Amendment and Revocation of Retained Direct EU Legislation) (EU Exit) Regulations 2018 (SI 2018/1407) (see Regulation 5) makes changes to retained direct EU legislation relating to air quality, to ensure that it continues to operate effectively.

<sup>4</sup> <https://uk-air.defra.gov.uk/air-pollution/daq>

### Nitrogen Dioxide

Based on the hourly mean concentration.

Index	1	2	3	4	5	6	7	8	9	10
Band	Low	Low	Low	Moderate	Moderate	Moderate	High	High	High	Very High
µg/m <sup>3</sup>	0-67	68-134	135-200	201-267	268-334	335-400	401-467	468-534	535-600	601 or more

### PM<sub>10</sub> Particles

Based on the daily mean concentration for historical data, latest 24 hour running mean for the current day.

Index	1	2	3	4	5	6	7	8	9	10
Band	Low	Low	Low	Moderate	Moderate	Moderate	High	High	High	Very High
µg/m <sup>3</sup>	0-16	17-33	34-50	51-58	59-66	67-75	76-83	84-91	92-100	101 or more

### PM<sub>2.5</sub> Particles

Based on the daily mean concentration for historical data, latest 24 hour running mean for the current day.

Index	1	2	3	4	5	6	7	8	9	10
Band	Low	Low	Low	Moderate	Moderate	Moderate	High	High	High	Very High
µgm <sup>-3</sup>	0-11	12-23	24-35	36-41	42-47	48-53	54-58	59-64	65-70	71 or more

**Figure 2-1 – Defra Air Quality Index**

### 3. MONITORING RESULTS

#### 3.1. NO<sub>2</sub> DIFFUSION TUBES

- 3.1.1. The results of the monitoring completed across the study area between 6<sup>th</sup> April and 15<sup>th</sup> July 2022 are provided in Table 1 below. The background colour assigned to each of the results corresponds to Defra's Air Quality Index.
- 3.1.2. All tubes were present during this monitoring period, and monitored concentrations were below the annual mean objective of 40µg/m<sup>3</sup>. Monitored concentrations were highest overall at the Vel 5 diffusion tube site which is located at Lamppost 7, Pendywyallt Road opposite No. 32. This location is closer to the roadside than residential premises, or nearby footpaths, and will be impacted from emissions from vehicle exhausts. Concentrations will be lower at the nearby residential properties which are set further back from the roadside. Monitored concentrations were lowest at the Vel 6 diffusion tube site which is located at Coryton Junior School and considered representative of background concentrations.

**Table 3-1 - Summary of NO<sub>2</sub> Diffusion Tube Concentrations**

Sampling Location	NO <sub>2</sub> Concentration (µg/m <sup>3</sup> )			
	Monthly concentrations			Annual Average (annualised and bias-adjusted)*
	From: 06/04/2022 To: 10/05/2022	From: 10/05/2022 To: 07/06/2022	From: 07/06/2022 To: 15/07/2022	
Vel 1	20.5	17.9	9.9	22.2
Vel 2	19.7	21.0	13.8	22.6
Vel 3	18.5	16.9	10.6	20.9
Vel 4	19.3	18.3	12.8	22.5
Vel 5	28.2	28.0	18.1	31.1
Vel 6	11.8	9.4	5.8	12.3
Vel 8	13.5	8.3	6.5	13.7

\* Following methodology in LAQM.TG(16)<sup>5</sup>, a local bias adjustment factor was used. The annual average data is calculated using all diffusion tube monitoring data to date (i.e. includes data presented in the May quarterly report).


<sup>5</sup> Defra (2021) Local Air Quality Management Technical Guidance (TG16) April 2021.

## 3.2. ZEPHYR CONTINUOUS MONITOR

### Nitrogen Dioxide

- 3.2.1. Figure 3-1 shows the NO<sub>2</sub> data monitored at each of the Zephyr continuous monitors for the period 7<sup>th</sup> April to 15<sup>th</sup> July. A summary of the monitored concentrations is provided in

- 3.2.2. Table 3-2. The continuous monitor at Park Road had 100% data capture during the monitoring period. The monitor located at Hollybush Inn experienced a technical fault for part of July, the overall data capture at this monitor between 7<sup>th</sup> to 15<sup>th</sup> July was 90.1% which is still considered good.
- 3.2.3. Average NO<sub>2</sub> concentrations across the monitoring period at both the monitoring sites were well below the air quality objective of 40µg/m<sup>3</sup>. There were also no exceedances of the one-hour objective (200µg/m<sup>3</sup>) at either of the sites. Concentrations remained relatively stable during the monitoring period and concentrations at both monitors followed a similar trend. Average concentrations were similar in magnitude to those reported in the May quarterly report.




**Figure 3-1 - Monitored Zephyr NO<sub>2</sub> Concentrations (µg/m<sup>3</sup>)**

**Table 3-2 - Summary of NO<sub>2</sub> Concentrations**


Monitor	Location	NO <sub>2</sub> Concentration Summary (7 <sup>th</sup> April to 15 <sup>th</sup> July 2022)	
		Average	Maximum
111	Lamppost 1, Hollybush Inn	17.4	70.6
942	Lamppost 15, Park Road	15.7	52.5

**Particulate Matter (PM<sub>10</sub> and PM<sub>2.5</sub>)**

- 3.2.4. Figure 3-2 and Figure 3-3 respectively, show the PM<sub>10</sub> and PM<sub>2.5</sub> data monitored at each of the Zephyr continuous monitors for the period 7<sup>th</sup> April to 15<sup>th</sup> July 2022. A summary of the monitored concentrations is provided in Table 3-3. The continuous monitor at Park Road had 100% data capture during the monitoring period. The monitor located at Hollybush Inn experienced a technical fault for part of July, and so had only 90.1% data capture.
- 3.2.5. Average concentrations of PM<sub>10</sub> and PM<sub>2.5</sub> at both the continuous monitors are below the respective annual mean objectives of 40µg/m<sup>3</sup> and 20µg/m<sup>3</sup> during the monitoring period. In addition, there were no 24-hour mean concentrations above 50µg/m<sup>3</sup>. Average concentrations were lower than those reported in the May quarterly report. Monitored concentrations follow a similar trend at both locations. A peak in data occurred in the early hours of the 10<sup>th</sup> April at the Hollybush Inn monitor, the same spike was not picked up at the Park Road monitor suggesting that it was a local pollution event, and not necessarily related to road transport.



**Figure 3-2 - Monitored Zephyr PM<sub>10</sub> Concentrations (µg/m<sup>3</sup>)**



**Figure 3-3 - Monitored Zephyr PM<sub>2.5</sub> Concentrations (µg/m<sup>3</sup>)**


**Table 3-3 - Summary of PM<sub>10</sub> and PM<sub>2.5</sub> Concentrations (7<sup>th</sup> April to 15<sup>th</sup> July 2022)**

Monitor	Location	PM <sub>10</sub> Concentrations (µg/m <sup>3</sup> )			PM <sub>2.5</sub> Concentrations (µg/m <sup>3</sup> )	
		Average	Maximum	Maximum 24-hour mean	Average	Maximum
111	Lamppost 1, Hollybush Inn	11.4	88.8	32.1	8.5	48.9
942	Lamppost 15, Park Road	10.5	43.1	30.5	7.9	27.3

### 3.3. DM11

#### Particulate Matter (PM<sub>10</sub> and PM<sub>2.5</sub>)

- 3.3.1. Figure 3-2 shows the PM<sub>10</sub> and PM<sub>2.5</sub> data monitored at the DM11 Pro monitor for the period 7<sup>th</sup> April to 15<sup>th</sup> July 2022. A summary of the monitored concentrations is provided in Table 3-3. The DM11 Pro was off-line for 11 hours on the 21<sup>st</sup> July, however, over the whole of the monitoring period the data capture was 99.6%.
- 3.3.2. Average concentrations of PM<sub>10</sub> and PM<sub>2.5</sub> at the continuous monitor are below the respective annual mean objectives of 40µg/m<sup>3</sup> and 20µg/m<sup>3</sup> during the monitoring period. In addition, there were no 24-hour mean concentrations above 50µg/m<sup>3</sup>. Average concentrations of PM<sub>10</sub> and PM<sub>2.5</sub> at the DM11 Pro were slightly lower than the Zephyrs, most likely as the DM11 Pro is located slightly further from the road than the Zephyrs.
- 3.3.1. The DM11 Pro was re-calibrated towards the end of June to ensure that the monitor was functioning correctly, which explains the step changes in the data between the 21<sup>st</sup> and 27<sup>th</sup> June. Outside of these dates both the PM<sub>10</sub> and PM<sub>2.5</sub> concentrations followed a similar trend.



**Figure 3-4 - Monitored DM11 Particulate Matter Concentrations ( $\mu\text{g}/\text{m}^3$ )**

**Table 3-4 - Summary of  $\text{PM}_{10}$  and  $\text{PM}_{2.5}$  Concentrations (7<sup>th</sup> April to 15<sup>th</sup> July 2022)**

Monitor	Location	PM <sub>10</sub> Concentrations ( $\mu\text{g}/\text{m}^3$ )			PM <sub>2.5</sub> Concentrations ( $\mu\text{g}/\text{m}^3$ )	
		Average	Maximum	Maximum 24-hour mean	Average	Maximum
332	19 Park Road	6.1	23.5	12.1	5.1	22.5

## 4. SUMMARY


---

- 4.1.1. NO<sub>2</sub> diffusion tube monitoring was carried out at seven locations during the period 6<sup>th</sup> April to 15<sup>th</sup> July. Concentrations were continuously monitored at two locations using Zephyr monitors (NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub>) and at one location using a DM11 Pro (PM<sub>10</sub> and PM<sub>2.5</sub>) during the period.
- 4.1.2. Monitored concentrations of NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> across the study area have been below the relevant objectives within this monitoring period. NO<sub>2</sub> concentrations were highest overall at the Vel 5 diffusion tube site which is located at Lamppost 7, Pendywyallt Road opposite No. 32. This sample location is closer to the roadside than residential premises, or nearby footpaths, and will be impacted from emissions from vehicle exhausts.
- 4.1.3. Monitored concentrations of NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> using the Zephyr monitors followed similar trends at both locations. Average concentrations of PM<sub>10</sub> and PM<sub>2.5</sub> at the DM11 Pro were slightly lower than the Zephyrs, most likely as the DM11 Pro is located slightly further from the road than the Zephyrs.

# Appendix A

MONITORING LOCATIONS





**Key**

- Diffusion Tube Monitoring Sites

**Site Descriptions**


- Vel 1: Lamp-post 15 Park Road
- Vel 2: Lamp-post 17 Park Avenue
- Vel 3: Lamp-post 25 Pendwyallt Road
- Vel 4: Lamp-post 1 Hollybush Inn
- Vel 5: Lamp-post 7 Pendwyallt Road
- Vel 6: Coryton Primary School
- Vel 8: Coryton Primary School Side Access


**wsp**

TITLE:  
VELINDRE CANCER CENTRE  
CARDIFF

FIGURE No: FIGURE 1:  
NITROGEN DIOXIDE  
DIFFUSION TUBE  
MONITORING LOCATIONS

Contains Ordnance Survey data © Crown copyright and database right 2022.







The Forum  
Barnfield Road  
Exeter, Devon  
EX1 1QR

[wsp.com](http://wsp.com)